

No. 207 / 2026

SANITATION CERTIFICATE

FHC UDAYAMPEROOR - UDAYAMPEROOR GRAMAPANCHAYATH

This is to certify that the premises of Prabhath Public School

Ward & Dooi No. (XVII/74/A Udayamperoor Gramapanchayath) owned by/run by Siluy Jacob, Secretary, National Educational Social Trust

has been found fit for running Prabhath Public School,
Udayamperoor

as per the provisions of the KERALA PUBLIC HEALTH ACT - 2023. The water supply, utensils, provisions disposal of liquid and solid wastes satisfactory on my inspection (Dated 25/5/26).

This certificate is issuing on the basis of written request from Siluy Jacob, Secretary, National Educational Social Trust.

This certificate is issuing only for getting D&O Trade license from Udayamperoor Gramapanchayath. Renewing license for the year 2026-27


Udayamperoor

Date: 25/5/26




HEALTH INSPECTOR
FAMILY HEALTH CENTRE
UDAYAMPEROOR

HEALTH INSPECTOR
FAMILY HEALTH CENTRE
UDAYAMPEROOR


MANAGER

PRABHATH PUBLIC SCHOOL
Udayamperoor. P. O., Pin-682 307
Ernakulam (Dist.), Kerala State


PRINCIPAL

RABHATH PUBLIC SCHOOL
DAYAMPEROOR. P. O., PIN-682 307
ERNAKULAM DISTRICT, KERALA STATE



Telephone: 0484-2926286
email: qcsdlmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, NETTOOR -682040
WATER TEST- BACTERIOLOGY REPORT

Report No: NTR/382/05/2026

Report Issue Date: 15.05.2026

Customer Name & Address	Date of Receipt of Payment	12.05.2026
PRABHATH PUBLIC SCHOOL UDHAYMPEROOR P O ERNAKULAM 682307	Date of Sample received	12.05.2026
	Sample given by	Customer
	Sample Code	NTR/382/05/26
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	TAP WATER FOR DRINKING PURPOSE
	Sample Quantity	250ml
	Test performing date : 12.05.2026 TO 13.05.2026	


Sl.No	Characteristics	Unit	Acceptable Limit as per IS 10500-2012	Result
1	Total Coliform	CFU/100ml	Shall not be Detected/100ml	ABSENT
2	E-Coli	CFU/100ml	Shall not be Detected/100ml	ABSENT

Remarks:-

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory



Reviewed & Analysed By

Reena
Bacteriologist

End of Report

KWA/QCSDL/NTR/F-21	Issue Date : 22.09.21	Issue no:01
Rev No:13	Rev,Date :30.03.2025	Page 1 of 1


PRINCIPAL
PRABHATH PUBLIC SCHOOL
UDAYAMPEROOR, P. O., PIN-682 307
ERNAKULAM DISTRICT, KERALA STATE



Silvy Jacob
MANAGER
PRABHATH PUBLIC SCHOOL
Udayanperoor, P. O., Pin-682 307
Ernakulam (Dist.), Kerala State



Telephone: 0484-2926286
email: qcSDLmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, NETTOOR -682040
(NABL Recognized Sub Divisional Level Government Drinking Water Testing Laboratory)

WATER TEST REPORT

Report No: NTR/382/05/2026


Report Issue Date: 15.05.2026

CUSTOMER NAME & ADDRESS PRABHATH PUBLIC SCHOOL UDHAYMPEROOR P O ERNAKULAM 682307	Date of Receipt of Payment	12.05.2026
	Date of Sample received	12.05.2026
	Sample given by	Customer
	Sample Code	NTR/382/05/26
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	TAP WATER FOR DRINKING PURPOSE
	Sample Quantity	2L
Test performing date : 12.05.2026 TO 15.05.2026		

Sl.N o	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Colour	Hazen	IS 3025 (Part 4)-2021	5	<5
2	Odour		IS 3025 (Part 5)-2018	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	0.50
4	pH @ 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	7.63
5	Total Dissolved Solids (TDS)@180° C	mg/L	IS 3025 (Part 16)-2023	500	55.0
6	Total Alkalinity	mg/L	IS 3025 (Part 23)-2023	200	24.00
7	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-2025	250	12.40
8	Calcium (as Ca)	mg/L	IS 3025 (Part 40)-2024	75	11.20
9	Magnesium (as Mg)	mg/L	IS 3025 (Part 46)-2023	30	1.46
10	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	34.00

Remarks:-

- 1) The result stated above related only to the sample(s) submitted for testing by the customer .
- 2) The samples retain for 15 days from the end date of analysis
- 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory
- 4)BDL-Below Detection Limit
- 5)DL-Detectable Limit



Analysed and Reviewed Authorized By

TECHNICAL MANAGER

End of Report

KWA/QCSDL/NTR/21	Issue Date : 22.09.21	Issue no:01
Rev No:14	Rev,Date :30.03.2026	Page 1of 1

PRINCIPAL

PRABHATH PUBLIC SCHOOL
UDAYAMPEROOR. P. O., PIN-682 307
ERNAKULAM DISTRICT, KERALA STATE

MANAGER

PRABHATH PUBLIC SCHOOL
Udayamperoor. P. O., Pin-682 307
Ernakulam (Dist.), Kerala State





Telephone:0484-2926286

email:-qcslmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, NETTOOR -682040
WATER TEST REPORT

Report No: NTR/382/05/2026

Report Issue Date: 15.05.2026

PRABHATH PUBLIC SCHOOL UDHAYMPEROOR P O ERNAKULAM 682307	Customer Name & Address	Date of Receipt of Payment	12.05.2026
		Date of Sample received	12.05.2026
		Sample given by	Customer
		Sample Code	NTR/382/05/26
		Sample Name	Drinking Water
		Sample Condition	Good
		Source of Sample	TAP WATER FOR DRINKING PURPOSE
		Sample Quantity	2L
	Test performing date : 12.05.2026 TO 15.05.2026		

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Nitrate (as NO ₃)	mg/L	IS3025(PART 34/SEC.1)-2023	45	2.81
2	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2024	1	BDL(DL=0.1)
3	Acidity (as CaCO ₃)	mg/L	IS 3025 (Part 22)-1986(Reaffirmed 2019)	--	3.76
4	Electrical conductivity at 25° - C	µS/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)	--	83.70
5	Fluoride (as F)	mg/L	APHA23rdEdition 4500 - F D	1	BDL(DL=0.1)
6	Sulphate (as So ₄)	mg/L	IS 3025 (Part 24/Sec 1)2022	200	3.16
7	Residual Chlorine (RC)	mg/L	IS 3025 (Part 26)-2021	Minimum 0.2	Nil

Remarks:-

- 1) The result stated above related only to the sample(s) submitted for testing by the customer .
- 2) The samples retain for 15 days from the end date of analysis
- 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory
- 4)BDL-Below Detection Limit
- 5)DL-Detectable Limit



Analysed and Reviewed Authorized By

TECHNICAL MANAGER

End of Report

KWA/QC/DL/NTR/F-21	Issue Date : 22.09.21	Issue no:01
Ref No:13	Rev,Date :11.09.2024	Page 1 of 1

PRINCIPAL

PRABHATH PUBLIC SCHOOL
UDAYAMPEROOR, P. O., PIN-682 307
ERNAKULAM DISTRICT, KERALA STATE

MANAGER

PRABHATH PUBLIC SCHOOL
Udayampoor. P. O., Pin-682 307
Ernakulam (Dist.), Kerala State

